



SPARK ARRESTER

FIRE DEPARTMENT STANDARDS

Building Department City of Upland 460 North Euclid Avenue Upland, CA 91786

Arresters shall have a vertical height of not less than five (5) inches above the top of the flue.

Spark arrester top and sides shall be constructed of galvanized mesh with a minimum of sixteen (16) gauge and a maximum of twelve (12) gauge. Openings shall not exceed one-half ($1/2$) inch and not closer than three-eighths ($3/8$) inch. All seams shall be overlapped one (1) inch.

Arresters shall be securely fastened to the top of the chimney with a flange or securely fitted inside.

